

September 6, 2011

Mr. Bob Van Dyk
ExxonMobil Oil Corporation
2619 E. 37th Street
Vernon, CA 90058

Subject: Rule 1146 Compliance Plan

Dear Mr. Van Dyk,

The South Coast Air Quality Management District (SCAQMD) has reviewed your plan application submitted under Application No. 518008 for a Rule 1146 compliance plan that was received on January 5, 2011. The compliance plan is approved based upon the information submitted in your plan application indicating how your two Group III boilers (Permit Nos. D70812 and D95975) will achieve compliance with Rule 1146. In accordance with your selection, you shall come into compliance with oxides of nitrogen (NO₂) limit of 9 ppm or less on or before January 1, 2013.

Your plan application indicated the boiler operating under Permit D95975 will comply with the 9 ppm NO₂ limit "if [the] boiler becomes operational". If the boiler does not become operational, the permit for the boiler must be surrendered and the boiler must be de-activated with removal of the burner and all fuel piping on or before January 1, 2013.

To comply with these rule requirements, any modifications to the boilers that require permit applications shall be submitted and approved prior to altering the existing boiler configurations by the AQMD. Please note that the application submittal deadline to modify or alter the boilers in Group III is January 1, 2012.

If you have any questions, please call Ed O'Neal, Air Quality Engineer II, at (909) 396-2565.

Sincerely,

Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery & Waste Management Permitting

cc: Compliance
A/N 518008